

# LBS COLLEGE OF ENGINEERING, KASARAGOD

## QUOTATION NOTICE

No.D-2164/2022    EEE-4

Date: 23.11.2023

Sealed competitive quotations are invited for the supply of **12V 40 AH Tubular C10 Battery under buy back scheme** in the Software lab of EEE Department of this institution specified in the schedule attached. Super scribing quotations for the supply of item against Quotation No. **D-2164/2022 EEE-4** due on 14.11.2023. The rates quoted should be for the delivery of the items at the college. Quotations received after the time fixed on the due date is liable to be rejected. Maximum period required for the delivery of the items should also be mentioned.

The prices quoted should be inclusive of all taxes, duties etc. The quotationer shall also quote the percentage of rebate/discount if any offered by them against the items.

Special conditions if any or printed on quotation notice will not be applicable to the contract unless they are explicitly accepted in writing by the undersigned.

Due date and time and time for receipt of quotation	: 01.12.2023, 2 PM
Date and time of opening the quotation	: 02.12.2023, 3 PM
The designation and address of the officer	: The Principal
Date up to which the rates are to remain firm for acceptance	: 6 Months
To whom the quotation is to be addressed	: LBS College of Engineering Muliyar (P O), Kasaragod- 671542.



**PRINCIPAL**

**Encl:** Specification of item

Copy To:

1. College Website
2. Notice Board

## SPECIFICATION OF ITEMS

**Supply, Installation, testing & commissioning of 40AH Tubular Batteries for UPS under Buyback Scheme.**

<b>I. Batteries for Buy back</b>		
SL NO	SPECIFICATION, MAKE AND TYPE OF BATTERIES	Quantity (Numbers)
1	Exide 6EL40	20

II	<b>Supply, Installation, Testing and commissioning of Tubular Batteries for UPS with following specifications</b>		Quantity
1	Type	Tubular	16 numbers
	Voltage	12V	
	Storage Capacity	40AH, C10	
	Certification /Compliance	ISO	
	Warranty	4-year onsite warranty from OEM	
2	Cables	Required Interconnecting cables	

<b>Terms and Conditions</b>	
Delivery	At LBS College of Engineering, Povval, Muliya PO, Kasaragod.
Installation	All the batteries to be installed in to Existing 10KVA UPS system after removing the existing 16nos of 40AH batteries.
Taxes, duties & quoted Price	The Price quoted should be inclusive of all charges like GST, duties, levies, cess, Delivery charges, Installation charges and buyback.
Verification of old batteries	Manufacturer or their dealers who are interested to submit proposal can verify the batteries proposed for buy back on request in any working days between 10am and 4pm. Tenders should possess valid KSPCB/CPCB proof to transport the batteries on buy back scheme.
Proposals	All the Tenders should be with proposals for item I and II